ransier	nt Rental Application (FIRE) Obse	rvation Date Inspector Initials
Owner	Name	
Addres	SS	Cabin or Apt. #
Permit	No Date of Final	No. of Bedrooms
E tl a <u>E</u> tl	Building Department and Assessor's reco he discrepancies are resolved with the B application could incur a substantial dela Examples of discrepancies are: building s	equare footage, number of bedrooms, any indication tout a permit, non-permitted conversion, etc. which
RESID	DENCE SAFETY ITEMS	
	osted Address: Address numbers are required inimum of four inches tall with a 1/2 inch strol	to be reflective and plainly visible from street and a se.
[ ] <u>F</u>	ire Extinguishers: All fire extinguishers shal	comply with the following:
1. A	At least one (1) extinguisher of minimum 2-A	10-BC shall be provided for each building or occupancy.
2. E	Extinguishers shall be mounted no higher than	five (5) feet and no lower than (3) feet.
3. E	Extinguishers shall be underwriter laboratory o	r fire marshal listed or approved by the State Fire Marshal.
4. A	All extinguishers shall be conspicuously locate	d, readily available, plainly marked and near the kitchen.
	Extinguishers shall be located so that travel disse located in Barbecue and/or Fire Pit area.	tance shall not exceed 75 feet. Additional extinguishers shal
p	Extinguishers shall be of a serviceable type wit blastic hardware will not be acceptable. If extinagged by a licensed firm.	h metal neck and valve. Disposable extinguishers with nguishers do not have date stamped on bottle, they shall be
	osted Fire Escape Routes: Each unit shall have at identifies escape routes from the structure in	we a laminated notice (8 ½ x 11 inch minimum size) posted a visible location in each sleeping room.
sh		or sleeping purposes and rooms leading to the guest rooms installed in accordance with the approved manufacturer's
	O Detectors: Each floor shall be provided with cordance with the approved manufacturer's instance.	th Carbon Monoxide detectors that are installed in structions.
ins of	stalled to manufacturer's instructions and meet	d-burning stoves that are available for guest use shall be appropriate construction codes. Instructions for proper use nade available to guests. When they are not available for the use (padlocking or permanent screening).

Revised Date: July 10, 2018 Page 1 of 2

			nted heaters are in use, posting of potential in the floor grate shall be posted in the			
higher than 44" above the floor. T	Bedroom Emergency Escape: All bedrooms must have two exits. If one is a window, the sill must be not higher than 44" above the floor. The open area of the window must be at lease 5.7 square feet with a minimum open height of 24" and minimum width of 20". Window bars, grills or grating are not permitted.					
Other: If, at the time of inspection, a health or safety violation is observed by the inspector, the violation must be corrected prior to final approval from the Mariposa County Fire Department.						
Observation Result						
Observation Date	☐ Pass	☐ Fail	Inspector Initials			
Observation Date	☐ Pass	☐ Fail	Inspector Initials			
Observation Date	□ Pass	□ Fail	Inspector Initials			

Revised Date: July 10, 2018 Page 2 of 2